

## 県営太陽光発電所の運転状況(1)

○太陽光発電所 12時気象状況、発電電力量 [平成30年8月分]

日付	12時の気象状況					1日の発電電力量					
	日射量 (Wh/m <sup>2</sup> )	風速 (m/s)	風向 (°)	気温 (°C)	湿度 (%)	PCS1 発電電力量 (kWh)	PCS2 発電電力量 (kWh)	PCS3 発電電力量 (kWh)	PCS4 発電電力量 (kWh)	発電 電力量 (kWh)	送電 電力量 (kWh)
H30.8.1	911	2.9	98	33.1	41.4	1,600	1,594	1,715	1,673	6,582	6,468
H30.8.2	820	1.6	184	31.5	49.4	1,395	1,386	1,486	1,460	5,727	5,616
H30.8.3	880	2.8	93	30.2	50.3	1,536	1,525	1,642	1,608	6,311	6,203
H30.8.4	925	2.2	110	30.1	46.1	1,516	1,503	1,634	1,584	6,237	6,132
H30.8.5	68	1.4	137	28.3	64.0	296	296	309	301	1,202	1,125
H30.8.6	448	2.0	262	24.7	74.7	421	418	447	432	1,718	1,677
H30.8.7	352	0.9	231	21.4	76.5	674	672	717	705	2,768	2,730
H30.8.8	438	1.3	212	27.1	62.5	854	860	915	901	3,530	3,461
H30.8.9	371	0.6	166	28.2	72.8	674	671	713	696	2,754	2,698
H30.8.10	619	2.1	95	29.6	64.9	1,201	1,194	1,275	1,246	4,916	4,803
H30.8.11	791	2.7	88	27.1	63.1	1,323	1,311	1,406	1,378	5,418	5,330
H30.8.12	952	1.4	242	28.0	59.1	1,557	1,552	1,692	1,652	6,453	6,355
H30.8.13	924	1.6	239	30.2	54.6	1,561	1,555	1,690	1,644	6,450	6,344
H30.8.14	633	1.5	177	30.4	59.3	1,284	1,277	1,375	1,338	5,274	5,162
H30.8.15	905	0.9	219	33.0	54.2	1,308	1,300	1,407	1,372	5,387	5,273
H30.8.16	28	0.8	179	22.5	92.8	239	239	249	243	970	940
H30.8.17	292	2.7	228	18.4	72.3	1,183	1,178	1,257	1,232	4,850	4,807
H30.8.18	879	1.7	117	23.1	47.2	1,599	1,602	1,689	1,663	6,553	6,480
H30.8.19	916	1.8	245	25.5	51.1	1,540	1,533	1,641	1,607	6,321	6,242
H30.8.20	779	1.5	237	27.3	53.9	1,527	1,517	1,642	1,600	6,286	6,196
H30.8.21	876	1.1	211	31.0	57.6	1,517	1,517	1,650	1,608	6,292	6,185
H30.8.22	885	1.9	134	33.7	50.8	1,540	1,536	1,662	1,625	6,363	6,253
H30.8.23	896	1.2	251	34.4	53.3	1,574	1,570	1,714	1,667	6,525	6,349
H30.8.24	66	1.1	120	26.1	89.5	265	264	276	268	1,073	1,009
H30.8.25	462	1.4	151	30.7	66.5	729	728	773	759	2,989	2,913
H30.8.26	28	1.7	85	23.2	94.6	145	146	152	148	591	530
H30.8.27	373	2.3	95	24.2	69.3	583	581	618	602	2,384	2,344
H30.8.28	373	1.4	207	23.9	75.4	453	453	480	472	1,858	1,812
H30.8.29	190	1.1	252	21.7	85.9	375	376	394	389	1,534	1,478
H30.8.30	128	1.1	172	26.9	75.6	582	583	619	605	2,389	2,330
H30.8.31	64	0.5	187	23.3	93.9	151	151	159	154	615	478
小計(平均)	557	1.6	175	27.4	65.2	31,202	31,088	33,398	32,632	128,320	125,723

**【記事】**

- ・ 8/5 19:21~8/6 10:48 雷の影響による系統波及および構内地絡発生（発電停止）。
- ・ 8/9（夜間） 主要変圧器ダイヤル温度計修繕（最高指針付きに取替実施）。