

## 県営太陽光発電所の運転状況(1)

○太陽光発電所 12時気象状況、発電電力量 [平成30年9月分]

日付	12時の気象状況					1日の発電電力量					
	日射量 (Wh/m <sup>2</sup> )	風速 (m/s)	風向 (°)	気温 (°C)	湿度 (%)	PCS1 発電電力量 (kWh)	PCS2 発電電力量 (kWh)	PCS3 発電電力量 (kWh)	PCS4 発電電力量 (kWh)	発電 電力量 (kWh)	送電 電力量 (kWh)
H30.9.1	261	1.1	252	22.8	76.7	486	486	516	503	1,991	1,951
H30.9.2	791	1.1	230	24.4	69.1	956	958	1,021	1,005	3,940	3,881
H30.9.3	393	1.6	247	26.0	67.0	830	841	890	870	3,431	3,386
H30.9.4	604	1.6	213	27.9	64.1	937	935	994	969	3,835	3,768
H30.9.5	440	0.9	190	27.1	62.7	1,266	1,263	1,348	1,317	5,194	5,111
H30.9.6	254	1.0	188	27.7	56.6	1,226	1,229	1,316	1,280	5,051	4,968
H30.9.7	191	0.4	159	23.6	74.6	324	322	338	328	1,312	1,269
H30.9.8	174	0.9	197	21.9	86.0	400	399	417	407	1,623	1,578
H30.9.9	258	0.8	186	20.4	82.3	361	361	380	372	1,474	1,434
H30.9.10	364	1.5	187	23.9	67.3	576	577	612	599	2,364	2,322
H30.9.11	780	1.2	160	22.2	61.4	1,213	1,206	1,273	1,247	4,939	4,884
H30.9.12	517	2.0	173	20.6	55.7	1,152	1,154	1,240	1,211	4,757	4,718
H30.9.13	568	1.8	243	23.3	53.7	1,404	1,406	1,538	1,488	5,836	5,779
H30.9.14	735	1.5	240	26.1	61.1	1,433	1,435	1,553	1,518	5,939	5,864
H30.9.15	169	1.2	267	22.0	83.7	410	410	430	421	1,671	1,623
H30.9.16	838	1.7	257	27.1	52.0	1,273	1,270	1,376	1,339	5,258	5,188
H30.9.17	659	1.5	146	24.6	58.5	835	842	895	884	3,456	3,396
H30.9.18	606	1.2	223	23.2	50.2	1,214	1,221	1,313	1,285	5,033	4,991
H30.9.19	862	1.6	147	23.0	45.0	1,606	1,607	1,738	1,685	6,636	6,445
H30.9.20	326	1.1	246	20.8	65.2	701	702	748	723	2,874	2,839
H30.9.21	154	1.4	84	19.4	72.6	347	346	362	353	1,408	1,367
H30.9.22	396	1.7	248	20.5	86.7	668	671	709	687	2,735	2,698
H30.9.23	713	1.1	159	24.5	51.0	1,380	1,392	1,503	1,457	5,732	5,669
H30.9.24	310	0.7	251	22.8	68.8	436	437	462	443	1,778	1,739
H30.9.25	82	3.4	78	14.7	81.5	154	154	157	150	615	575
H30.9.26	865	1.6	149	20.5	57.9	1,268	1,277	1,361	1,322	5,228	5,188
H30.9.27	57	1.4	226	13.2	95.0	76	77	78	75	306	260
H30.9.28	598	1.0	228	21.4	55.3	1,359	1,357	1,443	1,403	5,562	5,512
H30.9.29	178	1.0	266	16.5	75.8	357	356	374	363	1,450	1,416
H30.9.30	303	0.9	149	19.8	78.5	456	456	481	470	1,863	1,727
小計(平均)	448	1.3	200	22.4	67.2	25,104	25,147	26,866	26,174	103,291	101,546

**【記事】**

- ・ 9/21 17:13~9/28 10:00 一部回路切り離し（海外多結晶30度 破損パネル1枚を含む14枚発電停止）。
- ・ 9/28 9:30~10:00 破損パネル取替実施（発電再開）。